CIBSE REPUBLIC OF IRELAND



Why join CIBSE



CIBSE Journal + App & Electronic Newsletter







The Society of Light and Lighting



Networking Opportunities



Special Interest Groups







CIBSE IRELAND

CPDs all around Ireland

Social events:

- Golf Luttrellstown Castle September 7
- CIBSE Ireland Dinner & Awards 30th November Burlington hotel
- CIBSE Ireland YEN 5-A-Side- May 31, 2018





Student awards DIT & WIT

SDAR Journal

Standards Development: NSAI

Regulations Development





CIBSE Ireland awards (part of CIBSE Dinner) Sponsored by



These awards are open to the design consultant and mechanical or electrical contractor

Submissions must be a joint entry by both the consultant and contractor.

There are three categories for the CIBSE Ireland Awards,

These are:—

Up to €2 million

Between €2 million and €5 million

Over €5 million

The categories are based on services cost e.g. mechanical or electrical



Completed submissions must be received by no later than **12pm on Friday, 27th July 2018**. You will receive an acknowledgement of receipt by return.

Pre-submission enquires must be received by 13th July 2018 and no later than 2pm.

The awards will be presented as part of the CIBSE Ireland 50th dinner celebrations in the Clayton Burlington Hotel, Burlington Road, Dublin 4 on Friday, 30 November 2018.



Project Summary:

Provide a synopsis of the project, You can include details of the client brief, design and installation details (500 words maximum).

Overall design approach and solutions:

Detail how the design team approached the project and decided on the solutions to the building services installation.

You may include interactions with other members of the design team to fulfil the correct interpretation of the client brief, e.g. interaction with the architectural team (500 words maximum).

Specific elements of excellence in design implementation:

Detail how design was brought to life by the mechanical and/or electrical contractors in terms of taking the design, adapting it (where applicable), how the challenges of certain aspects of the design/installation were overcome by the design and contracting team (500 words maximum).



Project delivery:

Provide details such as project timelines, budget plan throughout and the challenges related to this. You should also submit evidence of how the design and contracting team worked together to implement project delivery on time and within budget. (500 words maximum).

Highlight the project's key performance indicators:

Detail how the tendered design was brought to reality and where applicable, altered to improve the key performance indicators. This section can compare design stage, as-built energy performance targets, commissioning results etc. (500 words maximum).

www.cibseireland.org











Nearly Zero Energy Buildings and the revised Irish Part L of the Building Regulations

Eoin Doohan BE CEng MCIBSE Principal Mechanical Engineer, AECOM Dublin





Agenda

- Background to NZEB in Ireland
- Non domestic buildings
- Domestic buildings
- $-\,$ Schools
- Summary
- Questions, Answers and Discussion



AECOM In Ireland

AECOM



Nearly Zero Energy Buildings

14



Curragh Racecourse Redevelopment



AECOM Imagine it. Delivered.

Dublin Landings



LinkedIn EMEA HQ



Project Opera, Limerick



Dublin Airport Capacity Development



Central Bank of Ireland

Background to NZEB in Ireland

AECOM

What is NZEB?

-<u>N</u>early <u>Zero Energy</u> <u>Buildings</u>

 'Nearly zero-energy building' means a building that has a very high energy performance...The nearly zero or very low amount of energy required should be covered to a very significant extent by energy from renewable sources, including energy from renewable sources produced on-site or nearby'

• From article 2.2 of the Energy Performance of Buildings Directive (EPBD)

ΔΞΟΟΙ

Energy Performance of Building Directive (EPBD)

- Main European legislative instrument to improve energy performance of buildings
 - Original released in 2002 (Directive 2002/91/EC)
- Directive 2010/31/EU (recast)
- Article 4: Member States must set minimum energy performance requirements for new buildings, for the major renovation of buildings, and for the replacement or retrofit of building elements
- Article 9.1: 'Member States shall ensure that by 31st December 2020, all new buildings are nearly zero-energy buildings and after 31st December 2018, new buildings occupied and owned by public authorities are nearly zero energy buildings'

Energy Performance of Building Directive (EPBD)

- Establishment of a calculation methodology for energy performance
- -Minimum energy performance requirements
- -Established energy performance certificates for buildings
 - Mandatory display for buildings offered for sale or rent
- Establish inspection schemes for heating and air conditioning systems
- Draw up lists of financial measures to improved energy efficiency of buildings





Other Legislation

- Energy Efficiency Directive (2012/27/EU)
 - Establish long-term national building renovation strategies
 - Make energy efficient renovations to at least 3% of buildings owned and occupied by central government
 - Governments should only purchase buildings which are highly energy efficient
 - Retail energy sales companies to achieve energy savings of 1.5%
- Ecodesign Directive (2009/125/EC)
 - Minimum mandatory requirements for energy efficiency of products
 - Expanded in 2009 to include all energy related products (ErP)
- Energy Labelling Directive (2010/30/EU)
 - Framework for labelling regarding energy consumption



Ireland Implementation Timeline

- January 2017: Interim NZEB Specification for Public Sector buildings
 - New buildings owned and occupied by Public Authorities after 31st December 2018 must be NZEB
- December 2017: Part L of the Building Regulations 2017 for buildings other than dwellings
 - Work, material alteration or the change of use commences or takes place on or before 31st December 2018
 - Where planning approval or permission for buildings has been applied for on or before 31st December 2018, and <u>substantial work</u> has been completed by 1st January 2020
- February 2018: TGD-033 "School Building Projects and Compliance with Part L of the Building Regulations 2017"





AECON

Ireland Implementation Timeline

- January 2017: Part-L 2011 for Dwellings (amended)

- For information only
- April 2018: Part L of the Building Regulations 2018 for Dwellings issued for public consultation
 - Work, material alteration or the change of use commences or takes place on or before 31st March 2019
 - Where planning approval or permission for buildings has been applied for on or before 31st March 2019, and <u>substantial work</u> has been completed by 31st March 2021
 - Part F (Ventilation) also revised
 - Public consultation closes Friday 8th June 2018





How are the Regulations Derived?

- EPBD Annex I: Principle of Cost Optimality
 - AECOM 2013 reports on behalf of the SEAI for domestic and non domestic installations
 - Approx. 60% reduction in primary energy
- EU Commission 2016 Guidelines Oceanic Region
 - Offices: 40-55 kWh/(m².y) of net primary energy with, typically, 85-100 kWh/(m².y) of primary energy use covered by 45 kWh/(m².y) of on-site renewable sources
 - New single family house: 15-30 kWh/(m².y) of net primary energy with, typically, 50-65 kWh/(m².y) of primary energy use covered by 35 kWh/(m².y) of on-site renewable sources

Cost Optimality



Figure 6.1c: Results of the cost-optimal analysis (Office (AC), Macroeconomic costs, 4% discount rate)

Table 6.1: Economic Optimal Energy Performance Level in Primary Energy

Reference building	Primary Energy (kWh/m²/yr)	Sensitivity Range(kWh/m²/yr)
Retail (Air Conditioned)	239	227-338
Office (Natural Ventilation)	52	35-103
Office (Air Conditioned)	102	101-179
School (Primary – Natural Ventilation)	55	8-80
Hotel (Air Conditioned)	284	243-330

Table 7.1: Comparison Table

Reference building	Cost Optimal Level	Current	Ratio of current
	(kWh/m²/yr)	Requirements(kWh/m ² /yr)	requirements and cost
			optimal level
Retail (Air Conditioned)	239	726	
Office (Natural Ventilation)	52	247	The current
Office (Air Conditioned)	102	366	requirements are more
School (Primary – Natural Ventilation)	55	111	than 15% greater than
Hotel (Air Conditioned)	284	507	cost optimal
Average	146	391	

AECOM



Primary energy demand by sector in Ireland Source: SEAI



Energy related CO2 by sector in Ireland Source: SEAI





CO2 emissions per useful floor area Source: BPIE survey, Eurostat database 2011



Half of Irish dwellings are less than 30 years old, which makes it the youngest dwelling stock in Europe.

In dwelling energy usage in 2010, Ireland was 5% above the UK and 26% above the EU-27 average (compared to 36% above in 2006) (SEAI 2013)



Energy Usage per Dwelling Climate Corrected Source: ODYSSEE



NZEB & Non Domestic Buildings

AECOM

Building Fabric / U Values / Part L 2008 Recap

- Elemental Method
 - Max average elemental U Values as per table 2
 - Max Area of openings as per table 3

- Overall Heat Loss Method
 - Max Average U Value based on building Area:Volume ratio as per table 1
 - Subject to different max elemental U values

Maximum average elemental U- value (W/m²K)						
Fabric Elements	New Buildings & Extensions to Existing Buildings	Material Alterations to, or Material Changes of Use of, Existing Buildings				
Pitched roof, insulation	on.					
ceiling level	0.16	0.35				
Pitched roof, insulation on slope	on 0.20	0.35				
Flat roof	0.22	0.35				
Walls	0.27	0.60				
Ground Floors	0.25					
Other Exposed Floor	s 0.25	0.60				
External personnel doors, windows and rooflights	2.20	2.20				
Vehicle access and similar large doors	1.5	-				
NOTE I: Permitted a windows and rooflights described in Paragraph	verage U-value of extern s in buildings other than of 1.2.3.2.	nal personnel doors, dwellings may vary as				

Table I

METHOD Maximum area of openings for average U-value of 2. (W/m ² K)					
Building type	Windows and doors as % of the area of exposed wall	Rooflights as % of area of roof			
Residential buildings					
(where people					
permanently reside)	30	20			
Places of assembly					
offices and shops	40	20			
industrial and	15	20			
scorage buildings	13	20			
NOTES:					
Eor the purposes	of this calculation, dorn	ner windows in a ro			







Building Fabric / U Values

	Part L 2017		Part L 2008	
Building Element	Area Weighted Elemental U Value W/m ² .K	Max Average Elemental U Value W/m ² .K	Maximum Average Elemental U Value W/m ² .K (Elemental Method)	Max Average Elemental U Value W/m ² .K (Overall Heat Loss Method)
Pitched Roof	0.16	0.3	0.16	0.25
Flat Roof	0.2	0.3	0.2	0.37
Wall	0.21	0.6	0.27	0.37
Ground Floor	0.21	0.6	0.25	0.37
Other Exposed Floor	0.21	0.6	0.25	0.37
Door, Window, Rooflight	1.6	3.0	2.2	NA
Curtain Walling	2.8	3.0	NA	NA
Swimming Pool Basin	0.25	0.6	NA	NA

- Principle of 'Reasonable Provision' provides flexibility

• Roof, wall and floor element heat loss same as if area weighted figures used

CIBSE



Thermal Bridging

- Thermal Bridging Transmission Heat Loss Coefficient (H_{TB}) generally needs to be calculated
- -3 options
 - Use DHPLG Acceptable Construction Details
 - Use certified details e.g. NSAI / Agrément approved or BRE database
 - Use alternative details and default NEAP figures • Generally less beneficial in overall calculations

AECON

Air Tightness

- Air tightness testing mandatory
 - Min. value of 5m³/m²/hr @ 50Pa
- More emphasis on design and construction stage
 - Identify appropriate air barrier elements
 - Develop appropriate details
 - Establish responsibility for construction of details
 - Establish on site inspection regime / quality control procedures



AECOM

Solar Overheating

- Restrictive 25W/m² no longer applies
- Reference glazing systems provided
 - East facing
 - Full width glazing to a height of 1m
 - g value of 0.68
 - Frame factor of 10%
- Calculated from April to September
- CIBSE TM 52 overheating assessment 'recommended'









Building Services

- More stringent heat generator efficiencies
 - 93% for boilers >70kW
 - 86% for boilers <70kW
- Heat pumps must meet EcoDesign directive efficiencies
- Defined minimum controls / BMS for various heating systems
- Maximum specific fan power (SFP) reduced for various systems
 - 1.6W/I/s for centralised heating and cooling systems (excl. heat recovery etc.)
- -All motors > 1.1kW should have variable speed drives

ΔΞΟΟ/

Building Services

-Air handling unit leakage classification of minimum L2

- -Cooling system efficiencies as per EcoDesign directive
- -Minimum control requirements for ventilation systems
 - BMS required for all systems > 70kW effective rated output





AECON
Lighting

- Minimum controls as per Part L 2008
 - Manual switches (>6m to switch)
 - Daylight sensing switching / dimming
 - PIR's
 - Time controls
- Minimum standards for efficacy
 - Lower efficacies acceptable with better controls

General lighting in office, industrial and storage spaces		Initial luminaire lumens/circuit watt	
		60	
Controls Control Factor		Reduced luminaire lumens/circuit-watt ¹	
Column 1	Column 2	Column 3	
(a) daylight ² space with photo-switching with or without override	0.90	54	
(b) daylit ² space with photo-switching and dimming with or without override	0.85	51	
(c) unoccupied space with auto on and off	0.90	54	
(d)unoccupied space with manual on and auto off	0.85	51	
(e) space not daylit dimmed for constant illuminance	0.90 0.80 0.75	54 48 45	
a + c			
a + d			
b + c	0.75	45	
b + d	0.70	42	
e + c	0.8	48	
e + d	0.75	45	
General lighting in other types of space		The average initial efficac should be not less than 60 Iam lumens/circuit watt	
Display lighting		The average initial efficac should be not less than 22 lam lumens/circuit watt	

²The zones for which daylighting controls can be applied are described in NEAP zoning rule

Non Domestic Energy Assessment Procedure (NEAP)

- EPBD 2002/91/EC Article 3 mandated methodology to calculate energy performance in Buildings

- NEAP Introduced in Part L 2008
 - · Heavily based on UK National Calculation Methodology
 - Uses 'Simplified Building Energy Model' as developed by BRE
- NEAP calculates Primary Energy Performance Coefficient (PEPC) and Carbon Performance Coefficient (CPC)
- 'Reference Building' with defined fabric details, efficiencies etc.
 EPC & CPC = 1.0
- Part L defines maximum figures for EPC and CPC for 'actual' building



CIBSE

Non Domestic Energy Assessment Procedure (NEAP)

Parameter	Reference Values TGD L 2017	Reference Values TGD L 2008
Total Floor Area and Building Volume	Same as actual building	Same as actual building
Opening Areas	Side lit :Exposed facades will have windows with area that is the lesser of either: 1.5m high × full facade width OR 40% of exposed facade area Top Lit:12% of exposed roof area will be made up of roof-lights	Offices and Shops –windows and pedestrian doors are 40% of the total area of exposed walls
Walls	U=0.18 W/m ² K	U=0.27 W/m ² K
Roofs	U=0.15 W/m ² K	U=0.16 W/m ² K
Floor	U=0.15 W/m ² K	U=0.25 W/m ² K
Thermal bridging	Actual Length of Key Junctions x Advanced Ψ value	Add 16% to fabric heat loss
Window U Value	Side lit: 1.4 W/(m ² K) Top lit: 1.6 W/(m ² K)	2.2 W/(m ² K)
Solar energy and Light transmittance	Side lit: 0.40 Top lit: 0.71	0.72
Air Permeability	$5m^{3}/(hr.m^{2})$ Floor area <250m ² $3m^{3}/(hr.m^{2})$ Floor area >250m ²	10m ³ /(hr.m ²)

CIBSE

Non Domestic Energy Assessment Procedure (NEAP)

Parameter	Reference values TGD L 2017	Reference values TGD L 2008
Heating efficiency (heating and hot water)%	91% Gas Boiler	0.73 CoP
Cooling Seasonal Energy Efficiency Air conditioned building Ratio (SEER / SSEER)	4.5 / 3.6	SEER=1.67
Cooling where applicable (mixed mode) (SSEER)	2.7	-
Lighting	65 lm/circuit watt	divide the illuminance by 100, then multiply by 3.75 W/m ² per 100 lux
Occupancy Control	Yes (Manual-On-Auto-Off)	Local Manual Switching
Daylight Control	Yes (photo-electric dimming without back sensor control)	Local Manual Switching
Central Ventilation SFP	1.8 W/(I/s)	2 W/(I/s)
Variable speed control of fans	Yes	No
Renewable Energy Ratio	20% using photovoltaics	None

CIBSE

Renewable Energy Ratio (RER)

- Primary Energy from Renewable Sources : Total Primary Energy
 - Determined by NEAP
- Renewable Sources = Solar Thermal / Solar Photovoltaic / Biomass Systems / Biofuel Systems / Heat Pumps / Combined Heat and Power / Aerothermal / Geothermal / Hydrothermal / Wind / Biomass / Biogases
- Minimum RER of 20% with Maximum Permitted EPC of 1.0 and CPC of 1.15
- Minimum RER of 10% with Maximum Permitted EPC of 0.9 and CPC of 1.04
- CHP systems sized in accordance with CIBSE AM 12 Combined Heat and Power in Buildings







TIRSE

Commissioning and Construction Quality

- On site quality control of insulation installation, air barriers and thermal bridges
- Air tightness testing mandatory
- Ductwork leakage testing mandatory on high pressure ductwork
- Systems should be adequately commissioned to meet design requirements
- Commissioning plan required at design stage
- Adequate Operation and Maintenance manuals now a Building Regulation requirement



ΔΞΟΟ/

Solutions / Challenges

- How Renewable Energy Ratio will be met
 - Achieving RER with PV difficult on larger / high rise buildings
- CHW and LPHW options to meet high spec office requirements
- Revised NEAP not yet issued currently using interim measures
- Reduce primary energy less primary energy, less renewables
 - Mixed mode and natural ventilation

ΔΞΟΟ/

Existing Buildings

- New building U values apply to extensions

- Material alterations have revised U values (applies to new works only)

Building Element	Area Weighted Elemental U Value W/m ² .K	Max Average Elemental U Value W/m ² .K
Pitched Roof	0.16	0.35
Flat Roof	0.25	0.35
Cavity Wall	0.55	0.6
Other Wall	0.35	0.6
Curtain Wall	1.8	1.8
Door, Window, Rooflight	1.6	3.0
Ground Floor	0.25	0.6

Existing Buildings

 Material change of use requires minimum U values for all building elements if they exceed threshold

Building Element	Area Weighted Threshold U Value W/m².K	Area Weighted Elemental U Value W/m².K	Max Average Elemental U Value W/m².K
Pitched Roof	0.16	0.16	0.35
Flat Roof	0.35	0.25	0.35
Cavity Wall	0.55	0.55	0.6
Other Wall	0.55	0.35	0.6
Curtain Wall	3.6	1.8	1.8
Door, Window, Rooflight	3.6	1.6	3.0
Ground Floor	0.45	0.45	0.6
Other Exposed Floor	0.6	0.25	0.6

Existing Buildings

- Use 'Limiting Thermal Bridging and Air Infiltration Acceptable Construction Details' among other requirements
- Boiler efficiencies for extended systems must meet new system efficiencies
- Controls must be upgraded to minimum standards
- Minimum specific fan powers for new and extended systems
 e.g. 2.2W/l/s for ventilation systems with heating and cooling
- Lighting as per new building requirements

ΔΞΟΟ/

Major Renovations

- ->25% of the surface area of building envelope undergoes renovation
 - Cladding external surface
 - Dry lining internal surface
 - Replacing windows
 - Excludes painting / replastering
- Performance of entire building improved to 'Cost Optimal' levels
 - Upgrading oil / gas heating systems >15 years old
 - Upgrading direct electric heating controls
 - Upgrading cooling systems >15 years old
 - Upgrading lighting systems >15 years old OR systems with efficacy < 50lms/W

ΔΞΟΟ/

Major Renovations

- Alternatively meet Primary Energy Performance as per Table 13
 - Calculated using NEAP
 - Min Part L 2008 Office: 360 kWh/m²/yr
 - Min Part L 2008 School: 110 kWh/m²/yr

Table 13 Whole Building Cost Optimal Level		
Building Type	Major Renovation - Cost Optimal Performance kWh/m ² /yr primary energy	
Retail	338	
Air Conditioned		
Office Natural Ventilated offices and other Buildings	124	
Office Air Conditioned	180	
Hotel Air Conditioned	342	
Schools	60	
Other Air Conditioned Buildings	338	
Other Naturally Ventilated Buildings	124	



AECON

NZEB & Schools

Technical Guidance Document TGD-033 for Schools

- First edition released February 2018
- Covers new buildings and buildings with planning permission already granted / projects in architectural design



Technical Guidance Document TGD-033 – New Schools

-MPEPC < 0.9

- 10% on site renewables from photovoltaics
- Potential for biomass via ESCO
- Infiltration < 3m³/m²/hr

Backstop U Values
Roof 0.16 W/m²K
Floor 0.21 W/m²K
Glazing 1.4-1.6 W/m²K
Wall 0.21 W/m²K

- SBEM being revised based on Irish school data



Technical Guidance Document TGD-033

- Planning permission already granted / projects in architectural design
 - Fabric and infiltration backstops to be used
 - LED lighting
- Major Refurbishments: Cost Optimal
 - Boilers and Controls >15 yrs old
 - General Ventilation Systems > 15 yrs old
 - Lighting Systems > 15 yrs old
 - PV to be 'considered'

Technical Guidance Document TGD-033

- Traffic Light System for Ventilation

Carbon Dioxide (CO ₂) Traffic Light Display Indicator Ranges Optimum Range <1500ppm		
Green	Amber	Red
<1500ppm	1500 to 2000ppm	>2000ppm

NZEB & Residential

NZEB for Dwellings

- Part L 2017 (Amended) for Dwellings issued January 2017 (for information)

	TGD L Dwellings 2017 (Amended)	TGD L Dwellings 2011
Maximum Permitted Energy Performance Coefficient (MPEPC)	0.30	0.40
Maximum Permitted Carbon Performance Coefficient (MPCPC)	0.45	0.35
Renewables	10kWh/m²/a	10kWh/m²/a

- Dwelling Energy Assessment Procedure (DEAP) v3.2
 - Published by Sustainable Energy Authority of Ireland (SEAI)

NZEB for Dwellings

- Part L 2018 issued for public consultation
- Elemental U value method only
 - U values reduced for certain elements

	Part L 2017	Part L 2008
Building Element	Max Elemental U Value W/m ² .K	Max Elemental U Value W/m ² .K
Walls	0.18	0.21
Floor	0.18	0.21
Windows & Doors	1.4	1.6
Pitched / Flat Roof	0.16	0.16

- Renewable energy ratio of 20% instead of fixed renewables in kWh/m²/yr
 - CHP as alternative to RER

CIBSE

NZEB for Dwellings

- Max airtightness of 5m³/m²/hr & mandatory air tightness testing
- Recognition of overheating risk
 - Mitigation measures, e.g. blinds, may be required
- Minimum controls and efficiencies for heat pumps
- Higher efficiencies for ventilation systems
- Major renovation = >25% of building envelope undergoes renovation
 - Cost optimal levels
 - 125kWh/m²/yr in DEAP
 - Upgrade boilers & electric heating >15yrs old
 - Upgrade insulation at ceiling level

CIBSE

NZEB for Dwellings – Sample Options in Draft Part L

Туре	Heating	Ventilation	Renewables*
Semi Detached House	Gas Boiler	Continuous Mechanical Extract	5 no. PV
Semi Detached House	Gas Boiler	Natural Ventilation	5 no. PV
Semi Detached House	Gas Boiler	MVHR**	4 no. PV
Semi Detached House	Heat Pump	Continuous Mechanical Extract	Heat Pump
Mid Floor Apartment	Gas Boiler	MVHR**	3 no. PV
Mid Floor Apartment	Heat Pump	Continuous Mechanical Extract	Heat Pump

*All PV's based on 275W PV panels, E/W facing MVHR = Mechanical Ventilation with Heat Recovery

- Common items

- Medium thermal mass
- Thermal bridge factor of 0.05
- U Values: Walls = $0.13W/m^2$.K / Floor = $0.14W/m^2$.K / Ceiling $0.11W/m^2$.K / Glazing $0.9W/m^2$.K (triple glazed)

CIBSE

DEAP Methodology

- DEAP v3.2 to be replaced by web based DEAP4

- Hot water use now considered
 - Accounts for type of fitting
 - Accounts for electric showers
 - Low water use designs improve overall BER
- More detail on lighting
 - · Greater benefit for using low energy fittings
 - Prevents overdesigning
- Other items
 - Changes in how renewables are calculated
 - Primary energy factors based on 5 year average
 - Waste water heat recovery can be used

		Results Conformity with renewable energy technologies requirement	t - individual schemes	
menu -	Start		Total contribution	Part L renewable
New Assessment	Dimensions	Solar water heating system	1489.23	7.45
Save		Heat pump as main space heating system	0	0
Save As	Ventilation	Heat pump as secondary space heating system	0	0
Detailed Report	Distance in the second	Heat pump as main water heating system	0	0
Find existing record	Building elements	Wood/Biomass heater as main space heating syste	em 0	0
Log.h	Water heating	Wood/Biomass heater as secondary heating system	n 0	0
MPRN Address Search	Property and a second se	Wood/Biomass heater as main water heating ystem	0	0
tore Options	Ughting and internal gains	Contibution from CHP	0	0
Clear all fields	Net space heat	Total thermal	1489.23	7.45
Beport or Upload	demand	Total electrical	0.0	0
DEAP Manual	Dist. system losses and gains	Total thermal equivalent	1489.23	7.45
NYP Screen (NAS)				×
Tech bulletins	Energy requirements	Conformity with primary energy use and CO2 emissions limit	fation race immed	
About DEAP 3.2.1	Summer internal	Performance coefficient		
CHOCK PLOY AND		CPC 0.397 MPCPC	0.46 🖌	
Results	Results	EPC 0.397 MPEPC	0.4	

Δ=(())

Part F (Ventilation)

- Now includes 'Central Continuous Mechanical Extract Ventilation'
- Natural ventilation only acceptable for airtightness of <3 / >5 m³/m²/hr
- Competent designers & competent installers
- 'Installation and Commissioning of Ventilation Systems for Dwellings - Achieving Compliance with Part F 2018'
 - Checklists for installation and commissioning
 - Operation and Maintenance manuals required



Cost of NZEB

Estimated % Additional Cost to Comply with Part L 2017

Building Type	Additional Cost Range
Office	1.9% - 2.4%
Primary School	6.2% - 7.7%
Post Primary School	8.1% - 9.5%
Hotel	4.6% - 5.3%
Retail	2.4% - 3.0%
Mixed-use	1.3% - 1.5%
Residential - Housing	0.9% - 4.2%
Residential - Apartments	0.7% - 2.9%

Estimated Cost Uplift - School

Construction Costs (Excl VAT)	€/m²	Uplift
Basic Building Cost + Fitted Furniture	1,220.00	
Additional Costs to Comply with Part L 2017		
Increased width of cavity wall & insulation	21.46	1.76%
Increased thickness of floor insulation	38.06	3.12%
Increased thickness of roof insulation	13.77	1.13%
Triple glazed windows in lieu of double glazed	14.57	1.19%
Introduction of PV panels	31.98	2.62%
LED Light Fittings throughout	3.24	0.27%
Total - Additional Costs to Comply with Part L 2017	123.08	10.09%
Total Building Cost (Excl VAT)	1,343.08	
Basic Building Cost + Fitted Furniture	1,220.00	



Summary

How Does NZEB Impact Us?

M&E Engineer	Architect	Contractor	Client
More stringent specifications for HVAC systems	Increased requirements for Cons building fabric and air ins	Construction quality around insulation air tightness	Increased cost
More in depth building	tightness	Quality control for thermal bridging	Higher specification building
calculations (incl	Mandatory calculations for		services & controls systems
More collaboration from proje throughout the p	ect outset (pre planning) and project life cycle	Mandatory air tightness testing	Reduced running costs
Increased focus on site inspe	ections & construction quality	More emphasis during commissioning	More certainty on quality of building product

Manufacturers are vital for providing the innovative products that will shape the design solutions

CONTRIBUTING TO A BETTER ENVIRONMENT AND A SUSTAINABLE FUTURE!

AECON

It's not just about Energy!

Energy is only one part of building sustainability





Conclusions

- Revised Part L for Non Domestic Buildings is an extensive document that all should read
- Calculation methodology (NEAP) to be confirmed
 Q2 2018
- Part L for Dwellings in Public Consultation have your say!
 - DEAP v4 to be issued
- Next steps EU has committed to cut CO2 emissions by 40% by 2030
 - COM/2016/0765 policy document
 - More emphasis on Smart Technologies







Thank You

Questions, Answers & Discussion



Non Domestic – New Buildings - NZEB

Based on NEAP Methodology60% Improvement on Previous RegulationsImprovement in Fabric PerformanceImprovement in Efficiency of Systems

- 10% to 20% Renewable Energy





OPW – Lesson Lane



Domestic – New Buildings - NZEB



Durkan Homes – Citywest

25% Improvement on Current Regulations Same Fabric Performance

- Boiler with Increased PV
- Boiler with MVHR and PV
- Heat Pump



Primary Energy Factor

- Methodology outlined in EN ISO 52000 -2017
- Based on Irelands Energy Projections 2017
- <u>https://www.seai.ie/resources/publications/Irelands_Energy_Projections.pdf</u>




Renewable Energy Ratio

- Calculated in line with ISO 52000
- Included:
 - PV
 - Solar
 - Wind
 - Heat Pump
 - Biomass/ Biogas
 - District heating
 - CHP



thermally conditioned space 5 space outside thermal envelope 6

S2

6 substation (low/medium voltage and possible storage)

The Renewable Energy Ratio *RER* =

 $\frac{E_{Pren}}{E_{Ptot}}$ Primary Energy of the Renewables E_{Ptot} Total Primary Energy



Renewable Energy Ratio - General

PV/ Wind/Solar/Biomass/ Biogas/ District Heating

- Equation 1 Ep, _{ren} = Generated Energy x Fp, _{ren}
- Equation 2 Ep, tot = Generated Energy x Fp, ren + Generated Energy x Fp, nren

		E	fPnren	fPren on-site	EPnren	Epren on-site	EPtot	RER
		kWh			kWh	kWh	kWh	nrb-os
	PV/Wind	0.0	0	1.94	0.0	0.0	0.0	
+ Delivered energy	Other	0.0	0	1	0.0	0.0	0.0	
+ Delivered energy	Solar	0.0	0	1	0.0	0.0	0.0	
+ Delivered energy	Biomass	0.0	0.1	1	0.0	0.0	0.0	
+ Delivered energy	Biodiesel	0.0	0.3	1	0.0	0.0	0.0	
+ Delivered energy	Bioethanol	0.0	0.34	1	0.0	0.0	0.0	
+ Environmental energy	HP	0.0	0	1	0.0	0.0	0.0	
+ Saved energy	CHP	0.0	0	1	0.0	0.0		
+ Delivered energy	District Heating	0.0	0.6	0.6	0.0	0.0	0.0	
+ Delivered energy	Grid	0.0	1.94	0	0.0	0.0	0.0	
+ Delivered energy	Thermal	0.0	1.1	0	0.0	0.0	0.0	
TOTAL STEP A					0.0	0.0	0.0	





Renewable Energy Ratio – Heat Pump

Heat Pump

• Environmental Energy = (Htg Demand_{HP} - Consumed Energy_{HP})





Renewable Energy Ratio – CHP

CHP

• Saved Energy =

Heat $Demand_{CHP} \times [(PEF_{gas} / 0.9) + ((CHP_{eff_elec} \times PEF_{elec}) / CHP_{eff_heat}) - (PEF_{gas} / CHP_{eff_heat})]$







What is the NEAP Methodology







NEAP Methodology – Asset Rating – Part L

EPC/CPC is ratio of Actual Building to Reference Building Reference Building is defined in Part L





NEAP Methodology – Asset Rating – BER

BER is ratio of Actual Building to Notional Building Notional Building is not changing



NEAP Methodology – Asset Rating – Process Load





SBEM Development – Activity Database

-8	Activities	×	Activity Database X
Object selector Diffice_Op	penOff	÷	Activity Daily Schedule Weekly Schedule Annual Schedule General
Basics and Occupancy HVAC,	ventilation, lighting and equipment Sources Building Reg	lation Check	Activities
Name Office_OpenC Type CONDITIONE Build type Office Source CIBSE A Basics Max. Humidity Min. Humidity Cool Office_OpenOff_ Heat Office_OpenOff_ Set back	Dif ED ♥ Shared office space commonly of h For very high density with a corresp "Hinh Density Twick smace" ♥ Full name Open plan office Coupancy ♥ 100 % Cool ♥ 24 °C Heat ♥ 22 °C Latent gain	Description per density than a cellular office. Indingly high IT load, refer to Office_OpenOff_Occ 0.11 pers/m2 120 W/pers 39 %	Object selector B1_Office export to excel Basics and Occupancy HVAC, ventilation, lighting and equipment Sources Building Regulation Check. Name B1_Office Description Type CONDITIONED Areas to perform office work including offices and meeting rooms. It coin chude internal conidors providing access to the office spaces. It has making including and equipment activities or kithermates within the office space areas for Source Build, type B1 Offices and Workshop busine Full name Generic Office Areas Source CIBSE A & BRE estimates Full name Generic Office Areas Basics Full name Generic Office Areas Occupancy Max. Humidity 100 z Occupancy Max. Humidity 0 z People density 0.1111 Max. Humidity 0 22 vC Vers Latent gain 40.65 Set back temperature 12 vC Vers Latent gain 40.65 x
Diplect selector Diffice Basics and Occupancy HVA Lighting and equipment Lighting sch. Jiffed Number of luxes Display Lighting Equipment sch. Office Equipment w/m2 Latent Gain Record: K < (55 of 491)	Activities	Breaklation Check irrements 0.33 10 V2/p 10 10 V2/p 10	X Record: H K 6 of 286 H % No Filter Search Activity Daly Schedule Weekly Schedule Annual Schedule General Activities Object selector B1_Office Search Billion Billion Billion Billion Billion Sources Building Regulation Check Lighting and equipment Lighting and equipment HWS 0.1955 I/day/m2 Number of kxees 400 Luces Duidoor air 10 I/s/p Display Lighting 0 W/m2 Equipment sch. Other gains Other gains Equipment W/m2 11.77 W/m2 Latent Gain 0 x/m2
			Record: H 4 6 of 286 + H H T. No Filter Search

- BRE Research
- Irish Specific Requirements



SBEM Development – Tool

Example of some changes

- More than 1 source of Heating
- Variable Speed Pumps
- Demand Control Ventilation
- LED Lighting

Record selector Heating	<u> </u>	
General Heating Cooling System Adjus	tment Metering Provision System Controls Bi-val	ent Systems Zone Summary
% Load le	ft for the primary system 60%	
Heat Source Fuel	type SEff. Load	
LTHW boiler Sioma	85 20	
Heat pump (electric): air so 🗸 Grid S	iup, ied Electricity 🧹 🛛 400 🔤 20	
*		
	General Heating Cooling SystemAdjustment Metering	Provision Sustem Controls Bi-valent Sustems Zone Summaru
	Ductwork and AHU leakage 0.003267 ratio	Specific Fan Power for the system
	Has the ductwork been leakage tested?	Do you know the Specific Fan Power?
	No, use default leakage	C No, use the default 2.9 W/Vs
	Yes, it meets next CEN classification:	Yes, SFP for the system is: 1.8 W/l/s
	IClass D	
	Does the AHU meet CEN leakage standards?	Pumps Variable Speed Pump?
	No, use default leakage Yes, it meets next CEN classification:	No, constant speed pump
	Class L1	C LTHW only
		C Both LTHW and CHW
		Type With multiple pressure sensors in the system
dar Office		
Since	×	
V systems Ventilation Ventilation (cont) Exhaust I	ighting Lighting Controls Display Lighting Solar Coll	ector
al Ventilation Type	Does activity require high pressure drop a	air treatment? -
Natural Rechanical supply/extract	 Use default from Activitiy database 	
	C Use user value	☑ (Tick if yes)
ou know the Supple/Extract SEP?	wand controlled ventilation	
n use the default 1.5 W/	Demand control dependent on gas sensors	
	Flow regulation type	

Reco

HVA



NZEB Compliant Office Building – Interim Methodology

Fabric	Performance Specification
Heat Loss Walls	0.2
Roof	0.15
Heat Loss Floor	0.16
Glazing	1.8 – U value; 0.33 – Solar Transmission 0.60 – Light Transmission
Air Permeability	3 m3/hr/m2
Thermal Bridging	Equivalent to ACDs
Services Strategy	Natural Ventilation with Split System in meeting rooms Full M&T on Lighting and HVAC
Heating & DHW Efficiency	92%
Cooling SEER	3.5
Lighting	2.5 W/m2/100lux
Lighting Controls	Full Daylight and Occupancy
Renewable	Photovoltaics - 12% of floor area



NZEB Compliant Office Building – Interim Methodology

Fabric	Performance Specification
Heat Loss Walls	0.2
Roof	0.15
Heat Loss Floor	0.16
Glazing	1.8 – U value; 0.33 – Solar Transmission 0.60 – Light Transmission
Air Permeability	3 m3/hr/m2
Thermal Bridging	Equivalent to ACDs
Services Strategy	FCU Full M&T on Lighting and HVAC
Heating & DHW Efficiency	92%
Cooling SEER	3.5
Lighting	2.5 W/m2/100lux
Lighting Controls	Full Daylight and Occupancy
Renewable	Photovoltaics - 23% of floor area



NZEB Compliant Laboratory Building – Interim Methodology

Fabric	Performance Specification		
Heat Loss Walls	0.15		
Roof	0.13		
Heat Loss Floor	0.1		
Glazing	1.4 – U value; 0.33 – Solar Transmission 0.60 – Light Transmission		
Air Permeability	3 m3/hr/m2		
Thermal Bridging	Equivalent to ACDs		
Services Strategy	Natural Ventilation in Offices and Support Areas	VAV in Laboratories SFP 1.5 W/I/s HRV 70%	
Heating & DHW Efficiency	92%	92%	
Cooling SEER		3.71	
Lighting	1.5 W/m2/100lux		
Lighting Controls	Full Daylight and Occupancy		
Renewable	CHP providing 60% of DHW and Heating Photovoltaics - 3% of floor area		



Operational Energy Performance

ts of Part L of the Bui



MIND THE GAP

Display E	Energy C	ertificate		-	Sufferen w
BER for the build	ling detailed bek	~≈ C1	subday, the BCI are construintly present and a second present and the second se	Pedratine an appendix I CO, amazoni base pedator of BCR is per	
NAME OF B Breat Name One, Str Toen Name One, Toe County Name One, C	ULDING not Name Two, in Name Two, ounly Name Two	Duilding Type: Useful Plear Area Main Heating Fue Duilding Environs	(er) 2000000 1000000000000000000000000000000	DER No.: Date of Isease Valid Cavili Assessor No.:	XXXXXX Day More Day More XXXXXX
buildy Energy Cont Deliner 42 40 43 40 44 40 4				Contract D	kate (CO Indicator
HIGH ENERGY U	168	0 1			
HIGH ENERGY U	168	Previous Build	ng Energy Rolings		
HIGH ENERGY G Annual Energy U Yes out,Oeo Non Dechinal pathweise	Electrical (Manufly)	Previous Build	ng Energy Ratings	1	

Set Occupancy Set Weather Set Temperatures

Set Equipment

Set Usage Profiles

Set Water Demand

Actual Occupancy More Appropriate Weather Actual Temperatures Actual Equipment Actual Usage Profiles Actual Water Demand









Regulatory Impact Assessment





DHW Energy – Proposed Changes

Daily Hot Water Use





Lighting Energy – Proposed Changes

New buildings:

• Enters details based on design of the installed lighting, including Wattage, Efficiency and/or Lux levels.

Existing buildings:

• Enters default efficiency based on the lamp type/ rating with the lighting level fixed.





Updating DEAP Guidance based on previous consultation

- Fixed Cooling accounted for in calculation
- Allowance for 2 main heating systems where present
- High Heat Retention Storage Heaters
- Clarification re Curtain Walling and Window Systems
- Efficiency Adjustment to MVHR for uninsulated ductwork
- Waste Water Heat Recovery
- Inclusion of electric showers





Renewables

TICK BOX or FIT FOR PURPOSE ?





Renewables - What type is most appropriate

 Biomass Fuel delivery Fuel storage Access to fuel 	Heat PumpHeating DemandLocationNoise	Solar Panels Space Will it meet requirement
PhotovoltaicsSpaceOvershadingDemand for Electricity	CHP • Demand for Heat and Electricity on site	Wind Turbine Site Restriction Demand for Electricity
	 District Heating Appropriate for Client Site Restrictions 	





 Good practice in the design of homes

 TM60: 2018







Internal Environmental Quality - Overheating









Internal Environmental Quality - Ventilation



Engaging the Building User



Building Energy Rating

Advisory Report

This report provides advice on improving the comfort and condition of your home – reducing energy costs and improving your Building Energy Rating.

How your home performed - Legend at rear of report



E1 and average CO₂ is 75 kgCO₂/m²/yr equivalent to 8.2 tonnes of CO₂ produced per year. Date of Issue: Day/Month/Year Valid Until: Day/Month/Year Address Address Line 1 Address Line 2 Address Line 3 Address Line 4 Address Line 5 Eircode Year of Construction: 1977 Dwelling Type: Detached House

The average BER rating for similar homes is

BER D2

CO₂ 6.1

272 kWh/m²/vr

55 kgCO₂/m²/yr

BER No: XXXXXXXX Your <u>current</u>

Building Energy

Rating (BER)

CO₂ produced equivalent to

6.1 tonnes per year.

Your annual energy use

	Current Energy Costs#	Potential Costs	
Space Heating	€1,284	€807	
Hot Water	€453	€260	
ighting	€150	€85	
Total Costs	€1,887	€1,152	

You could save €735 per year and improve the warmth and comfort of your home

Potential rating

Total Floor Area: 109.8 m² Deap Version No: 3.2.1

* Figures show how much a home such as yours, based on standard occupancy, spends for space heating, hot water, ventilation and lighting. Excludes appliances.

Top ways to make your home more energy efficient[†]

Recommended Measures (Assuming recommendations for improvements are installed in the order they appear in the table below	Investment Cost (Approx)) (Individual)	Payback (Individual)		Rz imj BER	nting after provement kWh/m²/yr	Pot
Draught Stripping, Hot Water, Lighting, Fans	Vents €252	2 years		D1	254	
New Boller and Heating Controls	€2,019	4 years		C2	193	
Roof Insulation	€860	5 years		C2	181	
Floor Insulation	€933	6 years		C1	165	
Total for this package	€4,064		1	Total	saving	
Total for this package See page 3 for a full list of measures for t	€4,064 his property.		You	Total	saving	DI
Total for this package See page 3 for a full list of measures for ti ¹ Top Recommendations are based on cost with the EU Energy Performance of Buildir	€4,064 his property. optimal calculations in Igs Directive.	accordance	You Buil Rati	Total r <u>pot</u> ding ng (l	saving tential Energy BER)	BE 165 ki



im) BER	kWh/m²/yr	Per Year (Cumulative)
D1	254	€134
C2	193	€549
C2	181	€628
C1	165	€735
Total	saving	€735

R) C Wh/m²/yr 2 3.8 3.8 tonnes per year. 34 kgCO₂/m²/yr



Questions







